



210 ADDISON AVE, PO BOX 1867
TWIN FALLS, ID 83301
208-733-4250
Laboratory Supervisor: Brooke Crawford

PWS #: 5550221
LAKE AG
65 S 200 W
BURLEY, ID 83318

LAB ID # ID00911

COLIFORM BACTERIA ANALYSIS REPORT

Date Collected 6/1/2026
Time Collected 2:00:00 PM

Date Received 6/1/2026
Time Received 2:34:00 PM

Sample # 3012445311
Type S - ROUTINE SAMPLE
Location HANSEN CELLAR
Collector CAMERON WAITE

Chlorine Residual: ppm

Date of Original Positive:

Copy:

Test Performed	Method	Result
Total Coliform	SM9223BCT18	ABSENT
Escherichia Coli	SM9223BCT18	ABSENT

Completed Date: 6/2/2026

Analyzed: Date 6/1/2026

Analyst BC

Time 4:00:00 PM

Reviewed by:

SM9223B CT Standard Method 9223B Colilert Reagent
SM9223B CT18 Standard Method 9223B Colilert-18 Reagent
SM9223B CS Standard Method 9223B Colisure Reagent
SM9222BWMF Standard Method 9222 M-Endo



210 ADDISON AVE, PO BOX 1867
TWIN FALLS, ID 83301
208-733-4250
Laboratory Supervisor: Brooke Crawford

PWS #: 5550221
LAKE AG
65 S 200 W
BURLEY, ID 83318

LAB ID # ID00911

COLIFORM BACTERIA ANALYSIS REPORT

Date Collected 6/1/2026
Time Collected 12:28:00 PM

Date Received 6/1/2026
Time Received 2:34:00 PM

Sample # 3012445301
Type S - ROUTINE SAMPLE
Location RUDY OLD YELLER
Collector CAMERON WAITE

Chlorine Residual: ppm

Date of Original Positive:

Copy:

Test Performed	Method	Result
Total Coliform	SM9223BCT18	PRESENT
Escherichia Coli	SM9223BCT18	ABSENT

Completed Date: 6/2/2026
Analyst BC
Reviewed by: CB

Analyzed: Date 6/1/2026
Time 4:00:00 PM

SM9223B CT Standard Method 9223B Colilert Reagent
SM9223B CT18 Standard Method 9223B Colilert-18 Reagent
SM9223B CS Standard Method 9223B Colisure Reagent
SM9222BWMF Standard Method 9222 M-Endo



210 ADDISON AVE, PO BOX 1867
TWIN FALLS, ID 83301
208-733-4250
Laboratory Supervisor: Brooke Crawford

PWS #: 5550221
LAKE AG
65 S 200 W
BURLEY, ID 83318

LAB ID # ID00911

COLIFORM BACTERIA ANALYSIS REPORT

Date Collected 6/1/2026
Time Collected 10:18:00 AM

Date Received 6/1/2026
Time Received 2:34:00 PM

Sample # 3012445291
Type S - ROUTINE SAMPLE
Location GOLDAREZ APTS
Collector CAMERON WAITE

Chlorine Residual: ppm

Date of Original Positive:

Copy:

Test Performed	Method	Result
Total Coliform	SM9223BCT18	PRESENT
Escherichia Coli	SM9223BCT18	ABSENT

Completed Date: 6/2/2026

Analyzed: Date 6/1/2026

Analyst BC

Time 4:00:00 PM

Reviewed by: CB

SM9223B CT Standard Method 9223B Colilert Reagent
SM9223B CT18 Standard Method 9223B Colilert-18 Reagent
SM9223B CS Standard Method 9223B Colisure Reagent
SM9222BWMF Standard Method 9222 M-Endo



210 ADDISON AVE, PO BOX 1867
TWIN FALLS, ID 83301
208-733-4250
Laboratory Supervisor: Brooke Crawford

PWS #: 5550221
LAKE AG
65 S 200 W
BURLEY, ID 83318

LAB ID # ID00911

COLIFORM BACTERIA ANALYSIS REPORT

Date Collected 6/1/2026
Time Collected 12:25:00 PM

Date Received 6/1/2026
Time Received 2:34:00 PM


Sample # 3012445281
Type S - ROUTINE SAMPLE
Location MAVERICK
Collector CAMERON WAITE

Chlorine Residual: ppm

Date of Original Positive:


Copy:

Test Performed	Method	Result
Total Coliform	SM9223BCT18	ABSENT
Escherichia Coli	SM9223BCT18	ABSENT

Completed Date: 6/2/2026
Analyst BC
Reviewed by: 

Analyzed: Date 6/1/2026
Time 4:00:00 PM

SM9223B CT Standard Method 9223B Colilert Reagent
SM9223B CT18 Standard Method 9223B Colilert-18 Reagent
SM9223B CS Standard Method 9223B Colisure Reagent
SM9222BWMF Standard Method 9222 M-Endo



210 ADDISON AVE, PO BOX 1867
TWIN FALLS, ID 83301
208-733-4250
Laboratory Supervisor: Brooke Crawford

PWS #: 5550221
LAKE AG
65 S 200 W
BURLEY, ID 83318

LAB ID # ID00911

COLIFORM BACTERIA ANALYSIS REPORT

Date Collected 6/1/2026
Time Collected 10:32:00 AM

Date Received 6/1/2026
Time Received 2:34:00 PM


Sample # 3012445271
Type S - ROUTINE SAMPLE
Location HEYBURN HOUSES
Collector CAMERON WAITE

Chlorine Residual: ppm

Date of Original Positive:

Copy:

Test Performed	Method	Result
Total Coliform	SM9223BCT18	ABSENT
Escherichia Coli	SM9223BCT18	ABSENT

Completed Date: 6/2/2026
Analyst BC
Reviewed by: 

Analyzed: Date 6/1/2026
Time 4:00:00 PM

SM9223B CT Standard Method 9223B Colilert Reagent
SM9223B CT18 Standard Method 9223B Colilert-18 Reagent
SM9223B CS Standard Method 9223B Colisure Reagent
SM9222BWMF Standard Method 9222 M-Endo



210 ADDISON AVE, PO BOX 1867
TWIN FALLS, ID 83301
208-733-4250
Laboratory Supervisor: Brooke Crawford

PWS #: 5550221
LAKE AG
65 S 200 W
BURLEY, ID 83318

LAB ID # ID00911

COLIFORM BACTERIA ANALYSIS REPORT

Date Collected 6/1/2026
Time Collected 8:55:00 AM

Date Received 6/1/2026
Time Received 2:34:00 PM

Sample # 3012445261
Type S - ROUTINE SAMPLE
Location PAUL CELLAR
Collector CAMERON WAITE

Chlorine Residual: ppm

Date of Original Positive:

Copy:

Test Performed	Method	Result
Total Coliform	SM9223BCT18	ABSENT
Escherichia Coli	SM9223BCT18	ABSENT

Completed Date: 6/2/2026

Analyzed: Date 6/1/2026

Analyst BC

Time 4:00:00 PM

Reviewed by: CB

SM9223B CT Standard Method 9223B Colilert Reagent
SM9223B CT18 Standard Method 9223B Colilert-18 Reagent
SM9223B CS Standard Method 9223B Colisure Reagent
SM9222BWMF Standard Method 9222 M-Endo

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

LAKE AG

65 S 200 W
BURLEY, ID 83318

Collection Date	6/1/2026	Received Date	6/1/2026	Location	
Collection Time	10:32 AM	Received Time	2:34 PM	HEYBURN FIELDS	

Sample #	Test / Method Code	Results	Units	Date Analyzed	Analyst
712068331	TOTAL COLIFORM SM9223BQT	1730	MPN/100ML	6/1/2026	BC
712068332	E-COLI SM9223BQT	23	MPN/100ML	6/1/2026	BC

Reviewed By: CBassfield

Report Date: Tuesday, June 2, 2026

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

LAKE AG

65 S 200 W
BURLEY, ID 83318

Collection Date	6/1/2026	Received Date	6/1/2026	Location
Collection Time	12:41 PM	Received Time	2:34 PM	HAWKER

Sample #	Test / Method Code	Results	Units	Date Analyzed	Analyst
712068341	TOTAL COLIFORM SM9223BQT	548	MPN/100ML	6/1/2026	BC
712068342	E-COLI SM9223BQT	11	MPN/100ML	6/1/2026	BC

Reviewed By: C Brassfield

Report Date: Tuesday, June 2, 2026

MAGIC VALLEY LABS

210 Addison Ave / PO Box 1867

Twin Falls ID 83303-1867

Phone: (208) 733-4250

Fax: (208) 734-2539

LAKE AG


65 S 200 W

BURLEY, ID 83318

Collection Date	6/1/2026	Received Date	6/1/2026	Location	
Collection Time	12:51 PM	Received Time	2:34 PM	PELLA FIELDS	

Sample #	Test / Method Code	Results	Units	Date Analyzed	Analyst
712068351	TOTAL COLIFORM SM9223BQT	>2420	MPN/100ML	6/1/2026	BC
712068352	E-COLI SM9223BQT	15	MPN/100ML	6/1/2026	BC

Reviewed By:



Report Date: Tuesday, June 2, 2026

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539


LAKE AG

65 S 200 W
BURLEY, ID 83318

Collection Date	6/1/2026	Received Date	6/1/2026	Location	
Collection Time	1:13 PM	Received Time	2:34 PM	JOE'S	

Sample #	Test / Method Code	Results	Units	Date Analyzed	Analyst
712068371	TOTAL COLIFORM SM9223BQT	>2420	MPN/100ML	6/1/2026	BC
712068372	E-COLI SM9223BQT	<1	MPN/100ML	6/1/2026	BC

Reviewed By:



Report Date: Tuesday, June 2, 2026

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539


LAKE AG

65 S 200 W
BURLEY, ID 83318

Collection Date	6/1/2026	Received Date	6/1/2026	Location	
Collection Time	1:04 PM	Received Time	2:34 PM		TY BECK'S

Sample #	Test / Method Code	Results	Units	Date Analyzed	Analyst
712068381	TOTAL COLIFORM SM9223BQT	2420	MPN/100ML	6/1/2026	BC
712068382	E-COLI SM9223BQT	70	MPN/100ML	6/1/2026	BC

Reviewed By: _____



Report Date: Tuesday, June 2, 2026

MAGIC VALLEY LABS
210 Addison Ave / PO Box 1867
Twin Falls ID 83303-1867
Phone: (208) 733-4250
Fax: (208) 734-2539

LAKE AG

65 S 200 W
BURLEY, ID 83318

Collection Date	6/1/2026	Received Date	6/1/2026	Location	
Collection Time	1:52 PM	Received Time	2:34 PM	HANSEN FIELDS	

Sample #	Test / Method Code	Results	Units	Date Analyzed	Analyst
712068391	TOTAL COLIFORM SM9223BQT	1990	MPN/100ML	6/1/2026	BC
712068392	E-COLI SM9223BQT	6	MPN/100ML	6/1/2026	BC

Reviewed By: _____



Report Date: Tuesday, June 2, 2026

